

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3295-1454:100 Page 1 of 1

CATEGORY: Fire-Rated Door

LISTEE: American Door Manufacturing, 1488 Tillie Lewis Dr., Stockton, CA 95206
Contact: Randy Neto (209) 941-8852

DESIGN: Doors, particle board core swinging single, pairs or dual egress doors with Georgia Pacific's "Firestop II" meeting edges. Maximum size not to exceed 4' wide x 10' high for singles and 8' wide x 10' high for pairs or double egress. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20 Minutes for smoke and draft control assembly.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, CSFM and EEL labels.

APPROVAL: Listed as 20 minutes smoke- and draft-control door assembly when installed in a listed frame approved for the type of wall construction. A gasket must be installed to provide a seal where the door meets the stop on both sides and across the top.

10-04-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**